


# Schedule of Accreditation

issued by

## United Kingdom Accreditation Service

2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

 <b>UKAS</b> CALIBRATION <b>0616</b>  Accredited to <b>ISO/IEC 17025:2005</b>	<b>Yadav Measurements Private Limited</b>	
	<b>Issue No: 029    Issue date: 16 May 2017</b>	
	<b>Post Box 169</b> <b>Plot No. 373 - 375</b> <b>RiicoBhamashah Industrial Area</b> <b>Kaladwas</b> <b>Udaipur 313 003</b> <b>India</b>	<b>Contact: Mr B M Vyas</b> <b>Tel: +91 294 265 0127</b> <b>Fax: +91 294 265 0129</b> <b>E-Mail: yadav.measurements@ymllabs.com</b> <b>Website: http://www.ymlabs.com</b>
<b>Calibration performed by the Organisation at the locations specified</b>		

### Locations covered by the organisation and their relevant activities

#### Laboratory locations:

Location details	Activity	Location code
<b>Address</b> Post Box 169 Plot No. 373 – 375 RiicoBhamashah Industrial Area Kaladwas Udaipur 313 003 India	<b>Contact</b> Mr B M Vyas Tel: +91 294 265 0127 Fax: +91 294 265 0129 E-Mail: yadav.measurements@ymllabs.com	<u>Calibration:</u>  Electrical Flow  P

#### Site activities performed away from the locations listed above:

Location details	Activity	Location code
The customers' site or premises must be suitable for the nature of the particular calibrations undertaken and will be the subject of contract review arrangements between the laboratory and the customer	<u>Calibration:</u>  Electrical	S



Accredited to  
ISO/IEC 17025:2005

**Schedule of Accreditation**  
issued by  
**United Kingdom Accreditation Service**  
2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

**Yadav Measurements Private Limited**

**Issue No: 029 Issue date: 16 May 2017**

Calibration performed by the Organisation at the locations specified

DETAIL OF ACCREDITATION

Measured Quantity Instrument or Gauge	Range	Calibration and Measurement Capability (CMC) Expressed as an Expanded Uncertainty ( $k = 2$ )	Remarks	Location Code
<b>ELECTRICAL MEASUREMENTS</b>				
DC RESISTANCE	1 m $\Omega$ to 100 m $\Omega$ 100 m $\Omega$ to 1 $\Omega$ 1 $\Omega$ to 10 $\Omega$ 10 $\Omega$ to 10 M $\Omega$ 10 M $\Omega$ to 100 M $\Omega$ 100 M $\Omega$ to 330 M $\Omega$ 330 M $\Omega$ to 1 G $\Omega$	0.50 % to 0.20 % 0.20 % to 0.060 % 0.060 % to 0.0040 % 0.0040 % to 0.015 % 0.015 % to 0.12 % 0.12 % to 1.2 % 1.2 %		P
DC VOLTAGE	1 mV to 5 mV 5 mV to 10 mV 10 mV to 40 mV 40 mV to 1000 V	0.13 % to 0.030 % 0.030 % to 0.014 % 0.014 % to 0.0050 % 0.0050 % to 0.0040 %		P
DC CURRENT	1 mA to 100 mA 100 mA to 1 A 1 A to 20 A	0.010 % 0.010 % to 0.030 % 0.60 %		P
AC VOLTAGE	40 Hz to 1 kHz 1 mV to 1 V 1 V to 120 V 120 V to 700 V  1 kHz to 300 kHz 500 mV to 10 V  40 Hz to 70 Hz 10 V to 480 V  50 Hz 480 V to 11 kV	0.50 % to 0.15 % 0.15 % to 0.10 % 0.10 % to 0.13 %  0.40 %  0.011 %  0.25 %		P



Accredited to  
ISO/IEC 17025:2005

**Schedule of Accreditation**  
issued by  
**United Kingdom Accreditation Service**  
2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

**Yadav Measurements Private Limited**

**Issue No: 029 Issue date: 16 May 2017**

Calibration performed by the Organisation at the locations specified

Measured Quantity Instrument or Gauge	Range	Calibration and Measurement Capability (CMC) Expressed as an Expanded Uncertainty ( $k = 2$ )	Remarks	Location Code
AC CURRENT	70 Hz to 1 kHz 1 mA to 10 mA	0.040 % to 0.031 %		P
	40 Hz to 70 Hz 1 mA to 10 mA 10 mA to 50 mA 50 mA to 100 A 100 A to 120 A	0.040 % to 0.031 % 0.013 % 0.007 % 0.021 %		
	40 Hz to 1 kHz 1 mA to 1 A	0.35 %		
AC POWER/ENERGY Frequency range 40 Hz to 70 Hz  Voltage range 40 V to 320 V Single and three phase active and reactive power and energy $\cos$ or $\sin \Phi = 0.1$ to 1, capacitive and inductive	0.004 W/Var to 48 W/Var 0.2 W/Var to 9.6 kW/kVar 40 W/Var to 96 kW/kVar 400 W/Var to 115.2 kW/kVar	0.041 % 0.0080 % 0.0070 % 0.014 %	Current range 0.001 A to 0.05 A Current range 0.05 A to 10 A Current range 10 A to 100 A Current range 100 A to 120 A	P
Single and three phase apparent power and energy	0.04 VA to 48 VA 2 VA to 9.6 kVA 400 VA to 96 kVA 4 kVA to 115.2 kVA	0.056 % 0.013 % 0.013 % 0.021 %		P
AC POWER FACTOR	0 to unity, inductive or capacitive	0.0050		P
FREQUENCY	10 Hz to 225 MHz	$2.0 \times 10^{-5}$ to $1.0 \times 10^{-5}$		P



Accredited to  
ISO/IEC 17025:2005

**Schedule of Accreditation**  
issued by  
**United Kingdom Accreditation Service**  
2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

**Yadav Measurements Private Limited**

**Issue No: 029 Issue date: 16 May 2017**

**Calibration performed by the Organisation at the locations specified**

Measured Quantity Instrument or Gauge	Range	Calibration and Measurement Capability (CMC) Expressed as an Expanded Uncertainty ( $k = 2$ )	Remarks	Location Code
Calibration of specific test equipment				
EFT/B Generators				P
Peak voltage into 50 $\Omega$ & 1 K $\Omega$	0 V to 7 kV	3.0 %		
Rise and fall time	5 ns to 50 ns	5.0 %		
Burst period and period	15 ms to 300 ms	5.0 %		
Frequency	2.5 kHz, 5 kHz, 100 kHz	5.0 %		
Surge generator				P
Rise and fall time	0.5 $\mu$ s to 100 $\mu$ s	3.0 %		
Open circuit Voltage	0.5 kV to 15 kV	5.0 %		
Short circuit Current	0.2 kA to 7.5 kA	5.0 %		
Damped oscillatory generator				P
Voltage	0 V to 4 kV	5.0 %		
Rise time	1.0 ns to 1.0 s	3.5 %		
Frequency	100 kHz to 1 MHz	3.0 %		
Repetition rate	1.0 $\mu$ s to 1.0 s	3.0 %		
High frequency field uniformity calibration in GTEM/Anechoic chamber	<u>GTEM</u> (80 MHz to 1000 MHz)			S
	2 V/m	0.23 V/m		
	3 V/m	0.69 V/m		
	10 V/m	2.3 V/m		
	30 V/m	6.9 V/m		
	<u>GTEM</u> (1000 MHz to 3000 MHz)			
	2 V/m	0.30 V/m		
	3 V/m	0.96 V/m		
	10 V/m	3.0 V/m		
	30 V/m	9.0 V/m		



Accredited to  
ISO/IEC 17025:2005

**Schedule of Accreditation**  
issued by  
**United Kingdom Accreditation Service**  
2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

**Yadav Measurements Private Limited**

**Issue No: 029 Issue date: 16 May 2017**

**Calibration performed by the Organisation at the locations specified**

Measured Quantity Instrument or Gauge	Range	Calibration and Measurement Capability (CMC) Expressed as an Expanded Uncertainty ( $k = 2$ )	Remarks	Location Code
Three phase voltage dips and interruptions calibration				P
Phase angle	(0 to 360 °)	1.70 °		
Pulse rise/fall time	(0.1 to 5) μs	5.0 %		
Voltage at no load	Up to 240 VAC (P-N) & 415 VAC (P-P)	1.0 %		
Inrush current	30 A	3.0 %		
Time interval	6 ms to 5 min	3.0 %		
Overshoot & undershoot		5.0 %		
FLOW MEASUREMENTS				P
Gas quantity passed	0.001 m <sup>3</sup> to 0.01 m <sup>3</sup> 0.01 m <sup>3</sup> to 0.08 m <sup>3</sup> At flow rates of: 0.016 m <sup>3</sup> /hour to 6.6 m <sup>3</sup> /hour	0.25 % 0.16 %	Calibration medium: Air	
Gas flow-rate	0.016 m <sup>3</sup> /hour to 6.6 m <sup>3</sup> /hour At quantities passed of 0.001 m <sup>3</sup> to 0.01 m <sup>3</sup> 0.01 m <sup>3</sup> to 0.08 m <sup>3</sup>	0.25 % 0.18 %		
END				